



VENTILATION REPORT

Last update August 27, 2021

Name of School Facility	Type of School Facility Ventilation	Ventilation assessed	Running ventilation systems longer	Higher grade filters installed	Increased frequency of filter changes	Increased fresh air intake (windows and/or mechanical ventilation systems)	HEPA units deployed in portables, as needed	Standalone HEPA filter units in place
A R Kaufman PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	11
Abraham Erb PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Alpine PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Ayr PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Baden PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Blair Road PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Bluevale CI	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Brigadoon PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Cameron Heights CI	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Cedar Creek PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Cedarbrae PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Centennial PS (C)	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Central PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Chicopee Hills PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Clemens Mill PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Coronation PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Country Hills PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Edna Staebler PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Elgin Street PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Elizabeth Ziegler PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	9
Empire PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Floradale PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Forest Glen PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Franklin PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Glencairn PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5

Name of School Facility	Type of School Facility Ventilation	Ventilation assessed	Running ventilation systems longer	Higher grade filters installed	Increased frequency of filter changes	Increased fresh air intake (windows and/or mechanical ventilation systems)	HEPA units deployed in portables, as needed	Standalone HEPA filter units in place
Grand View PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Grandview PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Groh PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	8
Huron Heights SS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
J.W. Gerth PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Jacob Hespeler SS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	10
Janet Metcalfe PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	9
Jean Steckle PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	8
Keatsway PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Lackner Woods PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Laurelwood PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Lester B. Pearson PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Lexington PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Linwood PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Manchester PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Mary Johnston PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Meadowlane PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Millen Woods PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Moffat Creek PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
N.A. MacEachern PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Northlake Woods PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Park Manor PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	2
Parkway PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Pioneer Park PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Preston PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6

Name of School Facility	Type of School Facility Ventilation	Ventilation assessed	Running ventilation systems longer	Higher grade filters installed	Increased frequency of filter changes	Increased fresh air intake (windows and/or mechanical ventilation systems)	HEPA units deployed in portables, as needed	Standalone HEPA filter units in place
Prueter PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	28
Queen Elizabeth PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Queensmount PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	2
Riverside PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Rockway PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Ryerson PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Saginaw PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Sandhills PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Sandowne PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	4
Silverheights PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Sir Adam Beck PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Sir John A. Macdonald SS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	3
St. Andrew's PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	2
Sunnyside PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	3
U-Turn Kitchener-Waterloo SEC	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	3
Vista Hills PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	8
W.T. Townshend PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Waterloo CI	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Wellesley PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Westmount PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Westvale PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Williamsburg PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	8
Wilson Avenue PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Winston Churchill PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	11
Woodland Park PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5

Name of School Facility	Type of School Facility Ventilation	Ventilation assessed	Running ventilation systems longer	Higher grade filters installed	Increased frequency of filter changes	Increased fresh air intake (windows and/or mechanical ventilation systems)	HEPA units deployed in portables, as needed	Standalone HEPA filter units in place
Smithson PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	Yes	Yes	Yes	NA	29
Avenue Road PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	13
Breslau PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	11
Bridgeport PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	18
Centennial PS (W)	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Chalmers Street PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	9
Conestogo PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Courtland Avenue PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	12
Crestview PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	11
Doon PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	11
Driftwood Park PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	8
Eastwood CI	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	12
Elmira District SS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	13
Forest Heights CI	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	21
Forest Hill PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	8
Galt CI	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	15
Glenview Park SS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	21
Grand River CI	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	14
Hespeler PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	8
Highland PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	23
Hillcrest PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	11
Howard Robertson PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7

Name of School Facility	Type of School Facility Ventilation	Ventilation assessed	Running ventilation systems longer	Higher grade filters installed	Increased frequency of filter changes	Increased fresh air intake (windows and/or mechanical ventilation systems)	HEPA units deployed in portables, as needed	Standalone HEPA filter units in place
J.F. Carmichael PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
John Darling PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
John Mahood PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
King Edward PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	19
Kitchener-Waterloo C & VS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	15
Laurentian PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	8
Lincoln Heights PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
MacGregor PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	18
Mackenzie King PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	10
Margaret Avenue PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	9
New Dundee PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Preston HS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	9
Sheppard PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Southridge PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	15
Southwood SS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	11
St. Jacobs PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	13
Stanley Park PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Stewart Avenue PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	18
Suddaby PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	25
Tait Street PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	20
Trillium PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
Waterloo-Oxford DSS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	46

Name of School Facility	Type of School Facility Ventilation	Ventilation assessed	Running ventilation systems longer	Higher grade filters installed	Increased frequency of filter changes	Increased fresh air intake (windows and/or mechanical ventilation systems)	HEPA units deployed in portables, as needed	Standalone HEPA filter units in place
Westheights PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	5
William G. Davis PS	Partial Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	9

* Some measures may not be feasible within the context of a school facility/site and related building systems.

** High-Efficiency Particulate Air (HEPA)

*** All Portables Mechanically Ventilated